

Reference number: PA5.0100/02

Tender for the Design and Build of the Visitor Experience, including Fit-out, New Showcases, Dioramas, AV Development and Graphic Installations, using Environmentally Friendly Materials at St Thomas Tower in Marsascale

5th July 2023

Clarification Nos 2

Question:

Reference to the LOT 3 – Museum Grade Showcases

Tender Specs include reference that : **“Showcases shall be fitted with an Active Humidity Control system (stand alone tank).”**

Can you please confirm that **Active Humidity Control is required for ALL the display cases required to be quoted.**

Answer:

Kindly note that the Active Humidity Control is required for all display cases included in the tender.