

## Direttorat ghas-Sahha Ambjentali Sovrintendenza tas-Sahha Pubblika

Ministeru tal-Energija u Sahha

Our Ref. : DH 54/2015/561  
Your Ref. : PA 03604/15

Malta Environment & Planning Authority  
Attn. Perit Francesca Azzopardi  
Floriana  
P.O. Box 200  
Valletta.  
CMR01

27<sup>th</sup> October, 2015


**Re:** Application by Mr. Mario Farrugia  
**P.A. No:** 03604/15  
**Location:** It-Torri ta' San Tumas, Dawret It-Torri c/w Triq Is-Salini c/w, Triq Wignacourt, M'Scala

**There is no objection from this end provided that:**

- Applicant adheres with the copy of proposed sketch plan.
- Only the preparation light snacks and the serving of readymade foodstuffs could be carried out. The cooking of foodstuffs is to be strictly prohibited.
- Proposed toilets leading to food rooms should be provided with adequate ventilation and with an adequately ventilated ante room. Where natural ventilation is not possible, adequate extract ventilation by mechanical means is to be provided.
- Height of proposed food rooms should not be less than 7 ft 6 inches (2.29m).
- Proposed grease trap (unless self-cleansing)/gully traps are to be located in the open air.
- Prior to use, premises are to be regularly connected to the government main sewerage system, be provided with a supply of electricity and be provided with a supply of wholesome water from an approved source.
- All rooms (basement level)/food rooms including food stores are to be adequately ventilated. Where natural ventilation is not possible, adequate intake and extract ventilation by mechanical means is to be provided.
- To provide adequate measures for the hygienic disposal of refuse.
- Applicant is to take all the necessary measures to prevent above mentioned premises from being a statutory nuisance to neighbouring properties.
- All Building and Sanitary Laws & Regulations are to be strictly complied with.

Referred.

Paul Bezzina  
Senior Environmental Health Practitioner  
Reg No:045  
F/Director (Environmental Health)



**Environmental Health  
Directorate**

Superintendence of Public Health  
Ministry for Energy and Health

**HEALTH INSPECTORATE SERVICES, FOOD SAFETY UNIT  
SERVIZZI TA' L-ISPETTORAT TAS-SAHHA, TAQSIMA TAS-SIGURTA' FL-IKEL**

Environmental Health Directorate  
Continental Business Centre,  
Old Railway Track, Sta. Venera SVR9018.  
Tel: +356 21337333 Fax: +356 2134 4767  
Email: food.safety@gov.mt